

Whereas, Sec. 4-36 of the Gordon County Code of Ordinances incorporates certain Minimum Standard Building Codes for administration and enforcement in Gordon County. Pertaining to Electrical Codes, Sec. 4-36(C)(1)b. states:

b. *Electrical.* The provisions of the National Electrical Code shall apply to the installation of electrical systems, including alterations, repairs, replacement, equipment, appliances, fixtures, fittings and appurtenances thereto...

Whereas, Section 4-36 (c)(1)(b) is limited by the specific requirement of Sec. 4-51(d)(3) which requires in part:

“Wire size. Minimum wire size allowed for branch circuit work shall be #12 AWG.”

Whereas, the National Electrical Code provides sufficient guidance, requirements and specifications for branch circuit wiring exclusive of the specific requirement of Sec. 4-51(d)(3).

Now Therefore, it is hereby Resolved that Gordon County Ordinance Sec. 4-51(d)(3) is deleted such that branch circuit work shall be performed as required by the National Electrical Code.

This Amendment has been Resolved and Adopted this day of October, 2016.

Becky Hood, Chairman

Attest: _____
Annette Berry, County Clerk